

PPL Electric Utilities Corp.
Peak Load Day/Hour Data for the Calculation
of the 2010 Peak Load Contributions (PLCs)

PJM 2009 Coincident Peaks
Use in development of the 6/1/10 to 5/31/11 Capacity Peak Load Contributions

	Peak Date	Peak Time		Peak Load Value ² (MW)
		(Hour Beginning)	(Hour Ending)	
ICAP	8/10/2009	1600	1700	6775.1
ICAP	8/11/2009	1600	1700	6506.9
ICAP	8/17/2009	1600	1700	6852.7
ICAP	8/18/2009	1500	1600	6747.1
ICAP	8/20/2009	1600	1700	6353.8
ICAP Target¹	8/10/2009	1600	1700	6850.0

¹ Interrupted Load Added Back and Weather Normalized

² Metered Load with Interruptions Added Back

Five Coincident PJM Peaks from 10/1/08 to 9/30/09

[Based on the PJM Summer 2009 Weather Normalized Coincident Peaks](#)

Updated 10/16/2009

PPL Zone 2009 Metered Peaks
Use in development of the 1/1/10 to 12/31/10 Transmission Peak Load Contributions

	Peak Date	Peak Time		Peak Load Value (MW)
		(Hour Beginning)	(Hour Ending)	
TX	12/22/2008	1900	2000	7205.1
TX	1/14/2009	1800	1900	6946.4
TX	1/15/2009	1800	1900	7173.9
TX	1/16/2009	1700	1800	7414.2
TX	2/5/2009	1800	1900	7038.7
TX Target	1/16/2009	1700	1800	7414.2

Based on the PPL Zone Metered Peaks

Five PPL Zone Peaks from 11/1/08 to 10/31/09

Updated 10/23/2009