

**RULES FOR ELECTRIC METER
& SERVICE INSTALLATIONS**



Effective September 1, 1997
Updates All Previous Table

**Approved Meter Service Devices
TABLE 6**

**POLYPHASE
2 TO 6 POSITIONS
OVERHEAD & UNDERGROUND ENTRANCE
208/120 Volt Wye or 240/120 Volt Delta
200 Amp
7 Terminal**

MFG. & CATALOG #	SERVICE AMPS	NUMBER OF POSITIONS	WIRING COMPARTMENT LOCATION
MILBANK			
S-9098	200	2	Center

MOST RECENT CHANGES

DATE	MFG.	CATALOG #	STATUS	REASON
-------------	-------------	------------------	---------------	---------------

NOTES:

1. All meter bases listed in this table are "ringless" style.
2. All polyphase socket style bases must contain a lever bypass rated 100% continuous duty.
3. The manufacturer's catalog number must be stamped on the outside of the meter base so that it will be visible after the base is installed. The number must not be stamped on the cover.
4. When aluminum conductors are used, the electrical contractor must apply the corrosion inhibiting compound recommended by and in the manner prescribed by the cable manufacturer.
5. The third jaw from the left (as viewed from the front) on the bottom row of the seven jaw block must be connected to the neutral using a #14 awg or larger copper wire.