

POLE ATTACHMENT DATA SHEET - NON CABLE

PPL Pole No. _____	Telco Pole No. _____
Street Location _____	Name of Attacher _____
City/Boro/Township _____	Date _____

POLE TYPE: Wood Metal


ATTACHMENT TYPE:

- Vertical Banner (Size) _____ by _____ Banners must be vented and be no longer than 4 feet in length.
- Decorative Lighting
- Flag Bracket
- Holiday Decorations – Unlit
- Public Signs
- Other _____

CLEARANCE REQUIREMENTS:

- 40 inches below electrical wire/cable.
- 20 inches below street light bracket.
- 12 inches below street light supply cable.
- 12 inches below any communications cable.
- 10 feet over areas accessible to pedestrians only.
- 16 feet over driveway, alley or parking lot.
- 18 feet over street or highway.

NOTE: All attachments that extend 18 inches past the face or side of the pole must meet proper ground clearance requirements:
 Non cable attachments are prohibited on poles inaccessible to PPL mechanized equipment.
 Attachments on non-metal poles must be banded. Attachments on fiberglass poles are usually not permitted.
 All banners must be vented to reduce wind loading on poles.



Low Electrical or Communications Conductor
 Attachment Height _____

Method of Attachment

- Bolted
- Banded
- Screwed
- Other _____

— — — New Attachment Height (top) _____

— — — New Attachment Height (bottom) _____

Surface Type _____
 (Lawn, Driveway, Street, etc.)

Make ready work required by _____ to provide required clearance to proposed attachment Yes No
 (Company)

COMMENTS: _____

For PPL Use Only:

Field Checked by _____ Date _____