

RULES FOR ELECTRIC METER & SERVICE INSTALLATIONS



AUTOMATIC TRANSFER SWITCHES Break before make/Open transition

The following lists the manufacturers and model numbers that have been submitted on previous projects, reviewed by PPL EU, and accepted for use. If other manufacturers or models are proposed for use, please submit all pertinent technical information to PPL Electric Utilities for review.

Manufacturer's model number designation is subject to change by the manufacturer at their discretion.

This list will be updated as additional models / manufacturers equipment are reviewed. However, the review will be done on an as-need basis only or by specific request.

ASCO: 300 series 940 series (discontinued model) 4000 series (4ATS) 7000 series (7ATS, 7ATB, 7AUS, 7AUB)	CATERPILLAR: CTS
CUTLER-HAMMER: ATS – 600 module Contactor-based (AT or BI types) Magnum-based ATC-600 (AT or BI types)	GENERAC: GTS RTS
KOHLER: GLS KCT KSS	CUMMINS/ONAN: OT OTEC OTPC
RUSSELECTRIC: RMTD RMTBD	GE ZENITH: ZTS ZTSD ZTG ZTGD ZTGSE

Make-before-break autotransfer switches (closed transition) can also be used. However, complete information on the equipment, connection of facilities, and installation of equipment must be submitted for review for each project.