



1. UNDERGROUND SERVICE LATERAL FROM OVERHEAD DISTRIBUTION BY PPL SEE RULE 8.
2. POINT OF DELIVERY (TERMINAL CONNECTORS BY CUSTOMER AS SPECIFIED BY PPL).
3. HIGH VOLTAGE SERVICE EQUIPMENT (EXTERNALLY OPERABLE FUSED LOAD INTERRUPTER SWITCH OR CIRCUIT BREAKER AS SPECIFIED BY PPL). SEE CRS 6-09-199.
4. SUPPLIER SHALL SUBMIT DETAILED CONSTRUCTION DRAWING TO PPL FOR APPROVAL BEFORE CONSTRUCTING COMPARTMENTS. PPL FURNISHES DETAILED ELECTRICAL ARRANGEMENT OF TERMINATION AND METERING COMPARTMENTS. SEE CRS 6-09-199.
5. HIGH VOLTAGE SERVICE LATERAL TERMINATIONS BY PPL