

POLE ATTACHMENT DATA SHEET - CROSS STREET BANNER

Name of Attacher _____ Date Submitted _____

Banner Installation Date _____ Banner Removal Date _____

Pole Location (City/Boro/Twp) _____ County _____

Submitted by _____ Phone Number _____ E-mail Address _____

Mailing Address _____

GENERAL

- Banners are limited to community or charitable functions.
- Banners must be vented to reduce wind loading on poles.
- The owner will have the banner installed and removed in a safe manner.
- The banner may be installed for thirty days maximum. A two-week extension is available if the application is received by PPL three days minimum before the contract expires.

CLEARANCE REQUIREMENTS

- Any part of the banner or its attaching ropes/wires shall be a minimum of forty inches below any PPL electrical facility.
- The lowest point of the banner shall be:
 - 10 feet over areas accessible to pedestrians only.
 - 16 feet over driveway, alley or parking lot.
 - 18 feet over street or highway.

RESTRICTIONS

- Tie or band banners to poles. Do not use bolts or lag screws unless specifically instructed to do so by PPL.
- Do not attach to pole(s) that:
 - a. is inaccessible to mechanized equipment.
 - b. has an underground riser.
 - c. has a line switch operating handle from an airbreak switch.
 - d. has control wiring from an electronic OCR or capacitor to a control cabinet.
 - e. are made of metal.

BANNER DETAILS

Size of Banner _____ by _____ Banners can not be larger than 30 feet in width.

Material of Banner _____

Weight of Banner _____

Method of Attachment _____

Message as it Will Appear on Banner _____

Make Ready Work and Charges _____

Item No.	PPL Pole Number	Street Location	Top Attach Height	Bottom Attach Height
1				
2				
3				
4				
5				
6				
7				
8				
9				
10				
11				
12				
13				
14				
15				

Remarks: _____

For PPL Use Only:
 Field Checked by _____ Date _____