

# RULES FOR ELECTRIC METER & SERVICE INSTALLATIONS



## AUTOMATIC TRANSFER SWITCHES Break before make/Open transition

The following lists the manufacturers and model numbers that have been submitted on previous projects, reviewed by PPL EU, and accepted for use. If other manufacturers or models are proposed for use, please submit all pertinent technical information to PPL Electric Utilities for review.

Manufacturer's model number designation is subject to change by the manufacturer at their discretion.

This list will be updated as additional models / manufacturers equipment are reviewed. However, the review will be done on an as-need basis only or by specific request.

<b>ASCO:</b>		<b>Briggs and Stratton:</b>	
185 series		071045	071057
300 series (3ATS, 3ADTS, 03NTS, 3NDTS)		071046	071058
940 series (discontinued model)		071048	071068
4000 series (4ATS) (4ADTS)-Delayed		071049	071071
7000 series (7ATS, 7ATB, 7AUS, 7AUB)		071055	071095 (DirectPower Meter Mounted)
<b>CATERPILLAR:</b>		<b>CUMMINS/ONAN:</b>	
CTS		OT OTEC OTPC RA Series	
<b>CUTLER-HAMMER:</b>		<b>EATON:</b>	
ATS – 600 module Contactor-based (AT or BI types) Magnum-based ATC-600 (AT or BI types)		EGSU series	
<b>GE ZENITH:</b>		<b>GENERAC:</b>	
ZTS ZTSD ZTG ZTGD ZTGSE		GTS RTS series RXS series	
<b>GLOBAL POWER PRODUCTS – GENERLINK (Meter Collar) (C)</b>			
MA23-N, Non-Surge (30 AMP) MA23-S, Surge (30 AMP) MA24-N, Non-Surge (40 AMP) MA24-S, Surge (40 AMP)			
<b>KOHLER:</b>		<b>RUSELECTRIC:</b>	
GLS KCP KCS KCT KEP	KSS RXT RDT	RMTD RMTBD	
<b>THOMPSON TECHNOLOGY:</b>			
TS910 Series			

Make-before-break autotransfer switches (closed transition) can also be used. However, complete information on the equipment, connection of facilities, and installation of equipment must be submitted for review for each project.

**(C)** Indicates Change

02/2019