


<u>Voltage:</u> 1 phase, 7200V 3 phase, 4 wire WYE 7200/12,240V	<u>Amperage:</u> N/A	<u>Inverter Continuous Current</u> N/A
<u>Service Type:</u> Overhead/Underground	<u>Meter Type/Location:</u> Primary Metering	<u>Bus Bar Rating:</u> ≤20%



Rules: 12, 28
Date: 07/10/2023 Engr: JEU



REMSI Sketches 51-100
Sketch #59
6-52

0000-000-ST-6052
Custom ID: DCS 6-52
Revision: 09
Effective Date: 7/10/2023
Page 36 of 84

Sketch #59 (Cont.) Inverter-based renewable generation for DG capacity up to and including 20% of the load center bus bar rating for 12KV metering installations (cont.)

CUSTOMER FURNISHES, INSTALLS, MAINTAINS:

1. Load center
2. AC disconnect switch
3. Inverter(s) (includes metering and communication features), inverter shall be labeled as IEEE 1547/UL 1741 listed.
4. DC disconnect
5. Distributed Generation (DG) source
7. AC disconnect switch
9. Customer metering (optional)

PPL EU FURNISHES, MAINTAINS:

6. Wired communication between PPL DER Management Device and inverter.
8. PPL communication device to PPL network.

REMSI_S059P1.dwg

RULES FOR ELECTRIC METER AND SERVICE
INSTALLATIONS
PPL ELECTRIC UTILITIES CORPORATION

Rules: 12, 28
Date: 07/10/2023 Engr: JEU



REMSI Sketches 51-100
Sketch #59
6-52

0000-000-ST-6052
Custom ID: DCS 6-52
Revision: 09
Effective Date: 7/10/2023
Page 37 of 84

Sketch #59 (Cont.) Inverter-based renewable generation for DG capacity up to and including 20% of the load center bus bar rating for 12KV metering installations (cont.)

NOTES:

- A. Metering equipment. See appropriate sketch for service type and size to determine metering responsibilities.
- B. See PPL EU customer-owned generation website for more information.
- C. Application for customer-owned, inverter-based renewable generation must be completed. See customer-owned generation applications.
- D. PPL EU requires an independent electrical inspection. The inspector is required to verify the IEEE/UL listing of the inverter.
- E. Installation must adhere to requirements of National Electrical Code (NEC) article 690 and article 705.
- F. All labeling must be in accordance with NEC article 690.
- G. in addition to Note D, PPL EU will install permanent labeling on the meter base PPL EU catalog (CID 1012171) and pad mount transformer (CID 1012171) or pole mount transformer (CID 1013816) upon receipt of inspection.
- H. See REMSI sketches #30, sketch #31. Sketch #33, & sketch #34.
- I. If a neutral connection exists at the inverter, the inverter neutral shall be connected to the service neutral.
- J. If inverter output voltage > 480vac, customer must provide transformation to match PPL service voltage
- K. If inverter output voltage > 480vac, customer must provide external power source for PPL owned DER management device
- L. Customer shall contact PPL EU prior to any new installations depicted in this sketch.
- M. PPL requires a local RS-485 or ethernet communication interface, also referred to as a communication port, to be open and accessible for the company owned DER management device (IEEE 1547-2018, sec. 10.1.4).
- N. Installations with multiple inverters shall be networked together by the customer per manufacturer guidelines or RS-485 multidrop networking. A communication network diagram depicting port availability and networking design shall be included with the system's interconnection application.
- O. For inverters where an additional module or kit is required to make the communication interface/port available, the module or kit must be included as part of the installed system. Reference PPL's approved solar inverter list for specific information.
- P. In the event of an outage or interruption due to equipment failure, weather, etc., any connected DER systems may be temporarily interrupted during the service restoration process.

REMSI_S059P1.dwg

RULES FOR ELECTRIC METER AND SERVICE INSTALLATIONS PPL ELECTRIC UTILITIES CORPORATION	Rules: 12, 28 Date: 07/10/2023 Engr: JEU
--	---