

**RULES FOR ELECTRIC METER
& SERVICE INSTALLATIONS**



**Pad Mounted Metering and Termination Cabinet
Referencing Sketch 16 and Sketch 16A**

Table 1

**THREE PHASE, 4 WIRE 120/208 VOLT WYE
THREE PHASE, 4 WIRE, 277/480 VOLT WYE**

MFG.	MFG. PART NO.	DRAWING #	REVISION # (See Note #1)
<i>PENN PANEL</i>		PP-S600-16-480	5
<i>PENN PANEL</i>		PP-S600-16A-480 (3200A)	01
<i>EAST COAST PANELBOARD</i>	PPL-2000A-16-3R	S-0004-000029-00	G
<i>EAST COAST PANELBOARD</i>		A-151560	A (sheet 3 of 3)
<i>EAST COAST PANELBOARD</i>	PPL-3200A-16-3R	A-0004-000020-02	2

MOST RECENT CHANGES

DATE	MFG.	DRAWING#	STATUS	REASON
8/2019	<i>EAST COAST PANELBOARD</i>	S-0004-000029-00	Updated drawing to Revision G per field request	Mfg. updated drawing
11/2019	<i>EAST COAST PANELBOARD</i>	A-0004-000020-02	Added cabinet. Approved by Meter Eng and Large Power	Customer Request

NOTES:

1. Only currently listed drawing revisions are approved.

02/04/2020